

CE/KLNZ/Vendor/

No 2145

Date: 17 MAY 2016

To,
M/s. Gala Shrink Fit,
Survey No.5 to 9, Sanjan Pada,
Palghar Manor Road, Chahade, Palghar (E).

Sub: Vendor & GTP approval of Heat Shrinkable Cable Joints & Termination Kits from 11kV to 33kV under Infra/RAPDRP Scheme in Kalyan Zone.

Ref: 1) Your office request letter dated 28.03.2016
2) Factory inspection carried out on dated 02.05.2016

Dear Sir,

With reference to the above subject, it is to inform you that the proposal pertaining to Vendor & GTP approval of Heat Shrinkable Cable Joints & Termination Kits from 11kV to 33kV under Infra/RAPDRP Scheme in Kalyan Zone submitted by your office vide reference (1) has been scrutinized by this office in line with technical specifications of Heat Shrinkable Cable Joints & Termination Kits from 11kV to 33kV of MSEDCL & it is generally found in order and hence, approved.

The said approved GTP & vendor of above materials is applicable subject to final acceptance test and verification of Type test certificate valid upto five years at the time of material inspection at your factory. Further, other details as per MSEDCL specifications, Infra/RAPDRP tenders technical specification of Heat Shrinkable Cable Joints & Termination Kits from 11kV to 33kV & relevant IS should be complied. This approval stands cancelled, if there is any change in policy of MSEDCL and if your performance found unsatisfactory at any stage.

The Type Tests details are as under:

Sr. No.	Sample	Type Tests Number	Place of Testing
1	19/33kV Heat Shrinkable Through Joint, Heat Shrink Indoor Termination & Heat Outdoor terminations mounted on 3X185 sqmm 19/33kV XLPE Cable	DDCD-12738 (A) dated 27.08.2012	CPRL, Bangalore
2	19/33kV Heat Shrinkable Through Joint, Heat Shrink Indoor Termination & Heat Outdoor terminations mounted on 3X185 sqmm 19/33kV XLPE Cable	DDCD-12738 (B) dated 27.08.2012	CPRL, Bangalore
3	Heat Shrink Indoor & Outdoor terminations and heat shrink straight through joint	SC12314A dated 23.07.2012	CPRL, Bangalore

Office of the Chief Engineer

"Tejashree", 1st floor, Jahangir Meherwanji Road, Kalyan (West) - 421304.
Ph. (0251) - 2328283 / 2305959 Fax : 2329488. E-mail : cekalyan@mahadiscom.in

Sr. No.	Sample	Type Tests Number	Place of Testing
4	19/33kV Heat Shrinkable Indoor Termination & Outdoor terminations mounted on 3X185 sqmm 19/33kV XLPE Cable.	DDCD-12738 (C) dated 27.08.2012	CPRL, Bangalore
5	19/33kV Heat Shrinkable Indoor Termination & Outdoor terminations and straight through joint mounted on 3X240 sqmm 19/33 (36) kV XLPE Cable.	DDCD-14957 dated 23.12.2015	CPRL, Bangalore
6	3X240sqmm Aluminum Conductor, XLPE Insulated Galvanized steel Formed Wire armoured, PVC sheathed 19/33kV Cable with Heat Shrinkable Indoor termination Outdoor Termination & a straight through joint.	SC15658A dated 01.12.2015	CPRL, Bangalore

In addition, the above approval shall not relieve you from the responsibility & liability for ensuring the correctness & the correct interpretation for meeting the requirements of the specification and terms & condition of the tender technical specification of Infra/RAPDRP Project and relevant IS.

Thanking you,

Yours sincerely



(S.V. Jaltare)
Chief Engineer,
Kalyan Zone, Kalyan.

Copy s.w.r.to:

1. The Executive Director (Infra), MSEDCL, Mumbai.

Copy f.w.cs.to:

1. The Chief Engineer (Infra), MSEDCL, Mumbai.

Copy to:

1. The Superintending Engineer (Infra), MSEDCL, Kalyan.
2. The Superintending Engineer, O & M Circle, MSEDCL, Kalyan-I/Kalyan-II/Vasai/Pen.

Office of the Chief Engineer

"Tejashree", 1st floor, Jahangir Meherwanji Road, Kalyan (West) - 421304.
Ph. (0251) - 2328283 / 2305959 Fax : 2329488. E-mail : cekalyan@mahadiscom.in